

(1) Type Examination Certificate

(2) No. of the Type Examination Certificate: **ZP/B004/14**

(3) Product: **Anchor device type A**
Type: **ABS-Lock[®] X-First II**

(4) Manufacturer: **ABS Safety GmbH**

(5) Address: **Gewerbering 3, 47623 Kevelaer**

(6) The design of this product and any acceptable variation thereto are specified in the schedule to this type examination certificate.

(7) The certification body of DEKRA EXAM GmbH certifies that this product comply with the fundamental requirements of the standard listed under item 8 below. The examination and test results in the test and assessment report PB 14-009.

(8) The requirements of the standard are assured by compliance with

DIN EN 795:2012

(9) This Type Examination Certificate relates only to the design, examination and tests of the specified product in accordance to the standard list. Further requirements of the Directive apply to the manufacturing process and supply of this personal protective equipment. These are not covered by this certificate.

(10) This Type Test Certificate is valid until 2019-01-23

DEKRA EXAM GmbH
Bochum, 2014-01-24

signed: Wiegand
Certification body

signed: Mühlenbruch
Special services unit

We confirm the correctness of the translation from the German original. In the case of arbitration only the German wording shall be valid and binding.

Bochum, 2014-02-28
DEKRA EXAM GmbH


Certification body


Special services unit

- (11) Appendix to
- (12) **Type Examination Certificate**
ZP/B004/14
- (13) 13.1 Subject and Type
Anchor device type A
Type: ABS-Lock® X-First II

13.2 Description

The anchor device type: ABS-Lock® X-First II secures not more than 3 persons against fall from a height and is designed for installation to the ridge, the supporting structure of the roof.

The anchor device consists of a folded base plate (t = 3 mm) made of corrosion resistant steel. Machined into the centre of the base plate is a web 33 mm wide. Connecting thereto are two outwardly oriented legs (156 mm x 80 mm). Each leg has four holes (Ø 7 mm), by which the anchor device is fastened to the building structure with the appropriate fasteners.

Welded onto the web is a sleeve which supports a support made of corrosion-resistant steel. The support is made of round steel (Ø 16 mm) of maximum 350 mm height. Welded to the underside of the web is a securing nut M16. The purpose of the securing nut is to securely bolt the support. Bolted and secured to the upper end of the support is an eyelet (M16) to which the user secures the personal protective equipment against fall from a height.

The anchor device is designed for load stress in all directions parallel with the surface of the building structure.



Figure 1: Anchor device type: ABS-Lock® X-First II

- (14) Test and Assessment Report

PB 14-009, 2014-01-24